



Addendum Notice

This **ADDENDUM #1** forms a part of the Contract Document and modifies the original formal solicitation document.

Date	June 7, 2024
Addendum No.	ADDENDUM #1
Formal Solicitation Name	RFP-24-002 Cemetery Expansion Project

Mandatory Pre-Proposal Conference Jun 3, 2024:

At the mandatory meeting, an inquiry was made asking about the columns and ribbon curb details.

The columns shall be built 20 foot on center and shall be 16.5" X 16.5' square.

The required ribbon curb is to be built 6" wide x 18" depth.

Columbarium's are not included in the bid proposal. All columbarium's shall be provided and installed by the City of Winter Garden.

**PLEASE
NOTE**

Bidders are required to acknowledge receipt of **ADDENDUM #1** in the space provided on the Signature Sheet within the original formal solicitation document.

**FAILURE TO ACKNOWLEDGE ALL ADDENDA MAY BE
CAUSE FOR REJECTION OF THE RESPONSE.**